



State of New Hampshire
DEPARTMENT OF ENVIRONMENTAL SERVICES

6 Hazen Drive, P.O. Box 95, Concord, NH 03302-0095
(603) 271-3503 FAX (603) 271-5171



Aminda Daviduk
Mindas Realty LLC
P.O. Box 366
E. Hampstead, NH 03826

LETTER OF DEFICIENCY# WSEB 02-19
CERTIFIED MAIL 7099 3400 0002 9772 1879

Subject: Hampstead - Public Water System: Glenwood North (EPA # 1032090)

Dear Ms. Daviduk

The records of the Department of Environmental Services (DES) show that the Glenwood North water system is classified as a public water system (PWS), as defined by RSA 485:1-a. A PWS is defined as any water system supplying 15 or more services, or 25 or more people, for 60 or more days per year. As such, the water system owner is required to submit samples to the State laboratory or a State-certified laboratory for coliform bacteria analysis in compliance with NH Admin. Rule Env-Ws 325.

DES records show that the subject water system failed to submit bacteria samples and as a result Monitoring/Reporting (M/R) violations were issued for the following months:

January 2002 and March 2002

In view of the Monitoring/Reporting violations, DES believes the deficiencies can be corrected by taking the following actions:

By May 31, 2002, submit a water sample for bacteria analysis to the state laboratory, or a state-certified laboratory, in accordance with NH Admin. Rule Env-Ws 325; and

In the future, submit routine water samples monthly for bacteria analysis

In the event compliance is not achieved within this period, DES may take further enforcement action, including issuing an order requiring the deficiencies be corrected, initiating an administrative fine proceeding and/or referring the matter to the NH Department of Justice for imposition of appropriate penalties.

Please contact Alan Leach by phone at (603) 271-2854 or by e-mail at aleach@des.state.nh.us if you have any questions regarding this letter.

Sincerely,

COPY

Anthony P. Giunta, P.G., Administrator
Water Supply Engineering Bureau

cc: ☒ Gretchen Rule, DES Legal Unit
Proctor Wentworth, Town of Hampstead Health Officer
Joan Keezer, Owner's Representative
William Houser, Primary Operator
EPA, Region 1

h:\wseb\enfmnon\enforce\lods\bact\1032090 mr lod.doc

COPY